



Prepared

Halvor Dolva

Approved

Vegard Skiftestad Olsen

Doc. no.

MN-GS

Rev.

A

Date

07-11-2019

Evacuation during Gas Emergency

Light towers are placed in the corridor in the 2nd floor outside the Electrical Characterization Lab and inside the cleanroom close to the gas detectors.

A siren can be heard when a gas alarm is activated.

In the case of detected gas alarm, the relevant gas line will automatically be closed by the gas system.

- **When the sirens are triggered and the situation is not clarified, evacuate the building through an emergency exit.**
- **Make sure to activate the fire alarm manually before evacuation.**
- **Do not attempt to use elevators.** Elevators are tied to the fire detection system and are not available to occupants once the alarm sounds.
- **Assemble** at the area designated in MiNaLab's Emergency Action Plan and remain there until instructed by the **Emergency Coordinator** or the fire department that it is safe to re-enter the building.